

FIRE MARSHAL'S OFFICE FIRE ALARM REQUIREMENTS



- NFPA 72, 2007 Edition; NFPA 13, 2007 Edition.
- Smoke detection is required in common egress pathways and public areas.
- Concealed devices must be marked with LED or Placard.
- HVAC units must use remote reset indicators.
- DCVA tamper switches, if enclosed inside, do not require outside vault tampers. **Exception: PIVs and WIVs**
- Plans should be submitted in the 1/8", 3/16", or 1/4" per foot scale range if applicable.
- 3 sets of plans must be submitted for review (must include site address).

EVERETT MUNICIPAL CODE REQUIREMENTS

- Chapter 16.03
- Chapter 16.76



Please contact
Assistant Fire Marshal Jim Venturo
425-257-8124 (Office) 425-754-4551 (Cell)
jventuro@ci.everett.wa.us