



# BACKWATER PREVENTION DEVICE FINAL INSTALLATION CHECKLIST

Installation Company Name and Contact Info: \_\_\_\_\_

Date Backwater Prevention device (BWD) was installed: \_\_\_\_\_ Date this form was completed: \_\_\_\_\_

Installation Property Owner Name and Contact Info: \_\_\_\_\_

Property Address: \_\_\_\_\_

## Pre-Installation Inspection Checklist:

*All items must be checked 'Yes' in order for a BWD to be considered for installation*

Is there a basement or level of the house that is at or near assumed sewer main elevation?  Yes  No

Are there fixtures in the house located below the upstream sewer manhole rim elevation?  Yes  No

Is the side sewer currently UNPROTECTED from sewer backups (does not have a BWD installed)?  Yes  No

## Site Inspection Checklist:

*All items must be checked 'Yes' before inspection is considered complete*

Was side sewer TV inspected from building to sewer main?  Yes  No Condition: \_\_\_\_\_

Does side sewer have at least 1% slope from the building to sewer main?  Yes  No Describe: \_\_\_\_\_

Have all building sewer drain connections to the side sewer been identified and located?  Yes  No

Have all property storm drainage connections to the side sewer been identified and located?  Yes  No

Has property been evaluated for drainage deficiencies with findings communicated to property owner?  Yes  No

## Installation Details:

What type and brand of BWD was installed at this site (Clean Check BWV, Grinder pump, etc.): \_\_\_\_\_

Where was the device installed (general description, attach map)? \_\_\_\_\_

Was there any other sewer or storm drainage work completed in conjunction with the BWD work? Is so please describe: \_\_\_\_\_

## Installation Checklist:

Are all downspouts and site drainage disconnected from upstream of the BWD?  Yes  No Comments: \_\_\_\_\_

Does BWD positioning meets minimum slope requirement of >1%?  Yes  No Comments: \_\_\_\_\_

Can BWD be pulled out for inspection and maintenance after loosening thumb screw?  Yes  No

Is BWD locked into the proper position and thumb screw tightened?  Yes  No

Circle the BWD cover: irrigation cover (landscape area) / traffic load bearing cover (drive surface) / access hatch (building)

Was property owner shown the location of the installed BWD?  Yes  No Comments: \_\_\_\_\_

Property Owner's Signature: \_\_\_\_\_ Date: \_\_\_\_\_

Installer's Signature: \_\_\_\_\_ Date: \_\_\_\_\_